

# SLOFEC™ LS150 & ULTRASONIC VESSEL INSPECTION

**Client:** Client

**Facility:** Client's Facility

**Items Inspected:** BT Vessel

**Inspection Method:** SLOFEC™ & Ultrasonic's

**Date Commenced:** 13<sup>th</sup> January 2014

**Date of Completed:** 18<sup>th</sup> January 2014

**Type of Report:** Final Report

**Report Number:** K0xx-13/Jxx22



Unit 1, Howemoss Avenue  
Kirkhill Industrial Estate, Dyce  
Aberdeen, AB21 0GP  
United Kingdom  
Tel : +44 (0)1224-724744  
Fax : +44 (0)1224-774087

Unit 27-28  
Webb Ellis Industrial Park  
Rugby, CV21 NP  
United Kingdom  
Tel : +44 (0)1788-547294  
Fax : +44 (0)1788-547299



WWW.INNOSPECTION.COM

|                         |                                 |                      |  |
|-------------------------|---------------------------------|----------------------|--|
| <b>Client/ Facility</b> | <b>Vessel Inspection Report</b> | <b>Page 1 of 10</b>  |  |
| <b>BT Vessel</b>        | <b>Final Inspection Report</b>  | <b>K0xx-13/Jxx22</b> |  |

# **SLOFEC™ LS150 & MANUAL ULTRASONIC VESSEL INSPECTION REPORT**

|                         |                                 |                      |  |
|-------------------------|---------------------------------|----------------------|--|
| <b>Client/ Facility</b> | <b>Vessel Inspection Report</b> | <b>Page 2 of 10</b>  |  |
| <b>BT Vessel</b>        | <b>Final Inspection Report</b>  | <b>K0xx-13/Jxx22</b> |  |

## **Executive Summary**

As requested by Client; Innospection has carried out a SLOFEC™ (Saturation Low Frequency Eddy Current) inspection, on the Vessel identified as BT.

The inspection was conducted at the Client's Facility, from the 13<sup>th</sup> of January 2014 and completed on the 18<sup>th</sup> of January 2014.

This inspection report documents in detail the specific inspection that has been conducted; the individual technique and equipment utilised, and the results, observations and conclusions obtained.

This SLOFEC™ inspection indicated internal indications primarily at the 5-7 o'clock locations; with wall losses indicated up to and greater than 50%, of the original nominal manufactured wall thickness.

The corrosion appeared to be that of internal pitting, that was noted wide spread and most severe across the middle lower sections of this vessel. Random spot checking with Ultrasonic around the dome ends, nozzles, branches, take offs and SLOFEC™ scanner dead zones, also showed areas of wall loss present.

The lowest ultrasonic wall thickness measured, was found in zone 2 (please see the included appendix mapping), where a result of 3.6mm remaining wall was indicated.


|                         |                                 |                      |  |
|-------------------------|---------------------------------|----------------------|--|
| <b>Client/ Facility</b> | <b>Vessel Inspection Report</b> | <b>Page 3 of 10</b>  |  |
| <b>BT Vessel</b>        | <b>Final Inspection Report</b>  | <b>K0xx-13/Jxx22</b> |  |

## Content

|     |  |      |
|-----|--|------|
| 1.  | Test Object Data.....                      | 4    |
| 2.  | Inspection Task.....                       | 4    |
| 3.  | Inspection Personnel .....                 | 4    |
| 4.  | Inspection Volume .....                    | 5    |
| 5.  | Inspection Equipment .....                 | 5-6  |
| 5.1 | SLOFEC™ Equipment .....                    | 5    |
| 5.2 | Ultrasonic Equipment (if applicable) ..... | 6    |
| 6.  | SLOFEC™ Equipment Setting .....            | 6    |
| 7.  | SLOFEC™ Equipment Calibration .....        | 7-8  |
| 7.1 | Equipment Calibration .....                | 7    |
| 7.2 | Calibration Control .....                  | 7    |
| 7.3 | Calibration Samples .....                  | 8    |
| 7.4 | Change of Settings.....                    | 8    |
| 8.  | Inspection Procedures .....                | 8    |
| 9.  | Inspection Performance .....               | 8-9  |
| 9.1 | Scanner Movement .....                     | 8    |
| 9.2 | Scan Track Positioning.....                | 8    |
| 9.3 | Parameter Storage.....                     | 8    |
| 10. | Defect Analysis .....                      | 9    |
| 11. | Comments to Inspection .....               | 9    |
| 12. | Sensitivity Setting .....                  | 9-10 |
| 13. | Inspection Summary .....                   | 10   |
| 14. | Documentation .....                        | 10   |
| 15. | Signature .....                            | 10   |

## Appendix

- Appendix 1 : Section Track Scan Overview & Zone Scan Reports  
Appendix 2 : Ultrasonic Thickness Results

|                         |                                 |                      |  |
|-------------------------|---------------------------------|----------------------|--|
| <b>Client/ Facility</b> | <b>Vessel Inspection Report</b> | <b>Page 4 of 10</b>  |  |
| <b>BT Vessel</b>        | <b>Final Inspection Report</b>  | <b>K0xx-13/Jxx22</b> |  |

## 1. Test Object Data

Object Identification : BT Vessel

Location of Object : Client's Facility

Orientation of Scan : Longitudinal

Wall Thickness : Nominal 9.5 mm

Material : Carbon Steel with a painted coating.

Surface Condition : Generally clean and free from loose debris.

## 2. Inspection Task

As requested by Client, a SLOFEC™ (Saturation Low Frequency Eddy Current) inspection was performed on the BT Vessel located at the Client's Facility from 13/01/14 to 18/01/14.

The inspection was performed with a SLOFEC™ technology scanner, type LS150.

SLOFEC™ is regarded as a fast corrosion screening technique, detecting corrosion on either side of the wall inspected. This method of testing makes it practical to inspect storage vessels from the external surfaces, whilst they are still in service and at operating temperatures.

The SLOFEC™ inspection team consisted of qualified engineers from Innospection Ltd.

All areas described in Section 4 – Inspection Volume were inspected with the SLOFEC™ Scanner.

The inspection was to survey for evidence of internal and external corrosion.

## 3. Inspection Personnel

Lead  
Inspection Technician : Technician a, ET PCN level 2, UT PCN level 2 / 000000

Inspection Technician : Technician b, ET PCN level 2, UT PCN level 2 / 000001

Assistant : Technician c, ET PCN level 2 / 000002

|                         |                                 |                      |  |
|-------------------------|---------------------------------|----------------------|--|
| <b>Client/ Facility</b> | <b>Vessel Inspection Report</b> | <b>Page 5 of 10</b>  |  |
| <b>BT Vessel</b>        | <b>Final Inspection Report</b>  | <b>K0xx-13/Jxx22</b> |  |

#### **4. Inspection Volume**

The SLOFEC™ Scans were intended to be taken over 360° coverage of the general vessel body. Weather and time constraints lead to 6 specific zones being inspected (as per the appendix). The seam welds including the heat affected zones were not scanned.

All accessible areas of the vessel were targeted for inspection with the exception of specific dead zones, which could not be inspected due to the design of the scanner (i.e. the wheels of the scanner butted against weld beads).

The Dead Zone refers to the following areas:

- a. 15 mm on either side of any weld
- b. 15 mm on either side of any nozzles/off takes

#### **5. Inspection Equipment**

##### **5.1 SLOFEC™ Equipment**

The inspection system consisted of the following SLOFEC™ equipment and accessories:

Scanner : SLOFEC™ Scanner LS150 (width 150mm)

Description of Scanner : The SLOFEC™ Scanner LS150 is a handheld system equipped with permanent magnets and multiplexed electronics. 8 sensors each with a width of 18.75mm are located between the pole shoes. A trigger encoder is connected via a belt drive to one wheel. 2 wheels at the front and 2 wheels at the rear are adjustable in height for lift off.

Scanning Speed : 100% (approx.: 24m/min)

Eddy Current Instrument : IBM-AT-compatible computer with 2-frequency Eddy current plug-in cards.  
Type : eddyMax - EMC07/08.03

Eddy Current Sensors : 8 x EC-B-18.75mm

Software Version : EddyMax Eddy Current Multiplex Software  
With trigger use – SN 20000997 TMT  
Version 5.07.07.20

Cable : 30 metres of specific cable connection between the computer eddy current instrument and SLOFEC™ Pipe Scanner LS150

Reference Plate : 9.5mm from Innospection – S/N 265

Reference Defect : 20%, 40%, 60%, 80% FBH

|                  |                          |               |  |
|------------------|--------------------------|---------------|--|
| Client/ Facility | Vessel Inspection Report | Page 6 of 10  |  |
| BT Vessel        | Final Inspection Report  | K0xx-13/Jxx22 |  |

## 5.2 Ultrasonic Equipment

The Ultrasonic Equipment consisted of the following accessories:

GE – USM GO Ultrasonic Flaw Detector capable of both “A” scan display and digital thickness readout - **USMG009110981**  
5 MHz 10mm Ø twin crystal transducer  
2mm – 12mm carbon steel calibration step wedge

## 6. SLOFEC™ Equipment Setting

In general, the SLOFEC™ system is calibrated using sample test samples with artificial reference defects. The reference samples should be of the same material and thickness as the surface to be inspected.

In the case of a coating being present on the surface to be inspected, the average thickness of the coating (if applicable) should also be simulated on the reference sample for the calibration.

Typical reference defects that are used are flat bottom holes or conical bottom holes are with a diameter of 5mm, 10mm and 20mm.

The depths of the artificial reference defects are typically 20%, 40%, 60%, 80% and 100%.

For calibration, the SLOFEC™ system is driven over the reference defects and the channels are set (one sensor per channel) to give a sufficient sensitivity level for the detection of topside and underside corrosion defects.

The calibration is performed at beginning, after breaks, at the end of every shift or in the case of changes to the equipment.

The calibration results and reference defect data from the calibration sample, is always stored in the system.

The Eddy Current signal analysis is done online. The computerised equipment and the software allow the analysis of the signal amplitude [in div.] and signal phase [in °].

In discussion with the individual client, indications comparable with the reference defect indications can be marked on the floor and are usually recommended to be re-inspected by Ultrasonic examination.

|                  |                          |               |  |
|------------------|--------------------------|---------------|--|
| Client/ Facility | Vessel Inspection Report | Page 7 of 10  |  |
| BT Vessel        | Final Inspection Report  | K0xx-13/Jxx22 |  |

## 7. SLOFEC™ Equipment Calibration


### 7.1 Equipment Calibration

For internal corrosion detection, the differential mode was used. The frequency setting used for Channel 1-4 (differential mode) was 80 - 100 KHz.

The amplitude of the signals was set so that the artificial reference defect (Ø 8mm 80% depth) was set to 8 screen divisions. This is only classed as the initial pre-calibration setup and may then be further adjusted when the first true indication is detected and evaluated for depth, this by utilising the Ultrasonic pulse echo technique.

Optimum signal/noise ratio and signal phase separation between the internal defect indications and other indications were considered when selecting a suitable test frequency.

The differential channels of all the sensors were set so that internal defects were indicated in the vertical signal phase direction as shown in the diagram below. By moving the scanner in the positive forward direction, the internal defect signal would show the first peak down, followed by the second peak up with an upward movement.



Sample signal display of internal defect

### 7.2 Calibration Control

The general setting and calibration was performed at the beginning of the inspection, with all calibration data being stored digitally. Calibration controls were performed at the beginning and end of each working shift and after any other significant interruption (i.e. breaks or lunch). Re-calibration is also deemed necessary when significant changes are made to the settings of the equipment.

Calibration samples are used for the initial set-up and for the random check of operator's settings. Accuracy of sensitivity settings can only be evaluated and achieved, when the first true indication found on the item undergoing the test is verified by a U/T operator, with the corresponding depth of indication and SLOFEC™ sensitivity being adjusted accordingly. With this setting, external corrosion defects would be detected and distinguished by phase separation from the internal defects.



|                  |                          |               |  |
|------------------|--------------------------|---------------|--|
| Client/ Facility | Vessel Inspection Report | Page 8 of 10  |  |
| BT Vessel        | Final Inspection Report  | K0xx-13/Jxx22 |  |

### 7.3 Calibration Samples

The calibration samples are manufactured by Innospection Ltd in accordance to the setting standard requirements.

### 7.4 Change of Settings

In the event of any scanner adjustment, re-calibration is performed.

## 8. Inspection Procedures

The inspection was performed according to the following valid procedure:

SLOFEC Vessel Procedure No. InnoVSloVes-001-08 – Current Issue

## 9. Inspection Performance

### 9.1 Scanner Movement

The scanner assistant, who was in permanent communication with the SLOFEC™ operator, was responsible for positioning and moving the scanner on the pipe surface. The SLOFEC™ Scanner LS150 is marked clearly on the top with the FORWARD and BACKWARD directions so that all scan directions are made clear to the operator and assistant at all times. In addition, some visual contact between the operator and assistant was established during the inspection.

The scanner was moved manually with the scanned tracks being overlapped at all times.

All scans for the inspection were recorded in the forward position.

### 9.2 Scan Track Positioning

The six vessel zones inspected were marked circumferentially into equal tracks.

### 9.3 Parameter Storage

The Eddy Current testing parameter was set during the calibration and digitally stored according to the scan direction and lift off.

## 10. Defect Analysis


All indications which showed a clear signal phase direction similar to that of the reference defects and had signal amplitude equivalent to that of the test piece were subjected to analysis. Signals that are clearly out of the corrosion phase direction were not reported.

## 11. Comments to Inspection

It is recommended for future inspections that a canopy be erected over the vessel, before the inspection start date. The weather caused significant delays during this particular inspection. Also preferably the vessel bund area should also be emptied of water before inspection. The cleaning status of the vessel surfaces was found suitable for inspection. The general external surface was painted and in very good condition.

## 12. Sensitivity Setting

The general overview of the inspected areas with the results is presented in the attached colour scan reports with wall loss being represented in colour classes as shown in the Wall Loss Legend below:



**Below 20% wall loss** - Grey  
**20-30% wall loss** - Green  
**31-40% wall loss** - Blue  
**41-50% wall loss** - Yellow  
**Above 50% wall loss** - Red

### Note

Eddy Current inspection is an evaluation method of NDT; hence all results obtained are based upon the test piece used. Material and wall thickness of the test piece should be as near as reasonably practicable to the item under inspection. Artificial defects should be as near in size and shape as to the type sought.

Because SLOFEC™ signal amplitudes are an indication of defect depth and volume, the defect depth analysis by signal amplitude can only be done in comparison with artificial reference defects having varying depths.

|                         |                                 |                      |  |
|-------------------------|---------------------------------|----------------------|--|
| <b>Client/ Facility</b> | <b>Vessel Inspection Report</b> | <b>Page 10 of 10</b> |  |
| <b>BT Vessel</b>        | <b>Final Inspection Report</b>  | <b>K0xx-13/Jxx22</b> |  |

### 13. Inspection Summary

Significant internal corrosion was discovered during this vessel inspection.

The maximum wall loss found present was 50%>, with the minimum ultrasonic wall thickness result recorded in zone 2 being 3.6mm remaining wall.

The most severe wall loss was seen in the bottom half (5-7 o'clock) of the vessel and concentrated in the middle inspected section. The characteristic of the corrosion was determined to be corrosion pitting.

### 14. Documentation

The inspection result, parameters and data are stored in the Innospection Limited archive database system.

### 15. Signature

\_\_\_\_\_  
Lead Inspection Technician a  
Inspection Technician  
Innospection Limited

\_\_\_\_\_  
Senior Engineer Level 3  
Inspection Technician  
Innospection Limited





**APPENDIX 01**


**SLOFEC Scan Report**

|                |           |          |                             |
|----------------|-----------|----------|-----------------------------|
| Client         | Client    | Date     | 13/01/14 - 18/01/14         |
| Plant          | Facility  | K-No.    | K0xx-13                     |
| Subject        | BT Vessel | Operator | Technician a - Technician b |
| Identification |           |          | Innospection limited        |

 Inspected Areas



(Plan) Full Circumferential Internal Opened Out View (BT Vessel)  
Not to Scale



Client  
Location  
Vessel  
Identif.


Client  
Facility  
BT

Section  
Date  
K-No.

**Zone 1**  
13 to 18 January 2014  
0xx-13



Signal Y-component / angle analysis window  
set for indication of internal defects with  
approx. depth information




Client  
Location  
Vessel  
Identif.


Client  
Facility  
BT

Section  
Date  
K-No.

**Zone 2**  
13 to 18 January 2014  
0xx-13



Signal Y-component / angle analysis window  
set for indication of internal defects with  
approx. depth information




Client  
Location  
Vessel  
Identif.


Client  
Facility  
BT

Section  
Date  
K-No.

**Zone 3**  
13 to18 January 2014  
0xx-13



Signal Y-component / angle analysis window  
set for indication of internal defects with  
approx. depth information






Client  
Location  
Vessel  
Identif.


Client  
Facility  
BT

Section  
Date  
K-No.

**Zone 4**  
13 to 18 January 2014  
0xx-13



Signal Y-component / angle analysis window  
set for indication of internal defects with  
approx. depth information




Client  
Location  
Vessel  
Identif.


Client  
Facility  
BT

Section  
Date  
K-No.

**Zone 5**  
13 to18 January 2014  
0xx-13



Signal Y-component / angle analysis window  
set for indication of internal defects with  
approx. depth information




Client  
Location  
Vessel  
Identif.


Client  
Facility  
BT

Section  
Date  
K-No.

**Zone 6**  
13 to 18 January 2014  
0xx-13




Signal Y-component / angle analysis window  
set for indication of internal defects with  
approx. depth information





## **APPENDIX 02**

### **Ultrasonic Thickness Results**

|                     |  |               |  |
|---------------------|--|---------------|--|
| Client/<br>Facility | SLOFEC Vessel Inspection Report<br>LS150 | Page 1 of 4   |  |
| BT<br>Vessel        | Final Inspection Report                  | K0xx-13/Jxx22 |  |

|   |   |   |                                 |                        |                          |
|---|---|---|---------------------------------|------------------------|--------------------------|
| Report No<br>K-No 0xx-13  | Customer<br>Client                                      |   |                                 |                        |                          |
| Location<br>Plant, UK   |   |   |                                 |                        |                          |
| Project<br>B T Vessel   | Line No<br>N/A  |   |                                 |                        |                          |
| Description<br>Ultrasonic Thickness Inspection On Areas of SLOFEC Dead Zones  | Test Date<br>13-18 Jan 2014                             |   |                                 |                        |                          |
| Procedure No<br>InnoUTSD-001-12   | Material<br>Carbon Steel                                | Standard<br>BS EN 1714                                  |                                 |                        |                          |
| <b>Equipment</b>  |   |   |                                 |                        |                          |
| Couplant<br>Water Based Gel   | Equip. Manufacturer<br>GE USM                           | Model<br>GO   | Serial No.<br>USMG009110981     |                        |                          |
| <input checked="" type="checkbox"/> Visual  | <input checked="" type="checkbox"/> Time Base Linearity | <input checked="" type="checkbox"/> Amplifier Linearity | Calibration Block No<br>3536738 | Timebase Range<br>0-25 |                          |
| Serial No<br>26751  | Type<br>Twin Crystal                                    | Angle °<br>0  | Crystal Size(mm)<br>10          | Freq<br>(MHz)<br>5     | Basic Sens<br>(db)<br>58 |
| Test Restriction/Limitations:<br>Uneven covering of paint made some areas of UT inspection not possible.<br>Scaffold prevented some areas of deadzones to be inspected with UT. |   |   |                                 |                        |                          |


| <b>Ultrasonic Inspection Results</b>   |        |         |      |      |      |
|--|--------|---------|------|------|------|
| <b>Dome Ends</b>   |        |         |      |      |      |
| A UT reading was taken on the barrel, the knuckle of the dome end and 3 readings for each clock position as depicted |        |         |      |      |      |
| East Dome End  | Barrel | Knuckle | 1    | 2    | 3    |
| Position   | (mm)   | (mm)    | (mm) | (mm) | (mm) |
| 1 o'clock  | 12.7   | 12.0    | 12.5 | 11.8 | 11.2 |
| 2 o'clock  | 12.8   | 12.7    | 12.7 | 11.7 | 11.2 |
| 3 o'clock  | 12.0   | 12.0    | 11.8 | 11.7 | 11.4 |
| 4 o'clock  | 9.9    | 11.0    | 9.5  | 11.1 | 11.2 |
| 5 o'clock  | 11.7   | 9.6     | 12.4 | 11.4 | 11.3 |
| 6 o'clock  | 12.2   | 12.1    | 11.5 | 11.2 | 11.2 |
| 7 o'clock  | 12.4   | 11.8    | 12.2 | 11.4 | 11.2 |
| 8 o'clock  | 12.5   | 11.4    | 11.3 | 11.4 | 11.2 |
| 9 o'clock  | 11.8   | 11.0    | 11.4 | 11.6 | 11.2 |
| 10 o'clock   | 12.1   | 11.2    | 11.6 | 12.1 | 11.5 |
| 11 o'clock   | 12.1   | 11.6    | 12.2 | 11.6 | 10.9 |
| 12 o'clock   | 12.3   | 13.1    | 12.5 | 6.0  | 11.3 |


### Ultrasonic Inspection Results

#### Dome Ends

A UT reading was taken on the barrel, the knuckle of the dome end and 3 readings for each clock position as depicted

| West Dome End | Barrel | Knuckle | 1    | 2    | 3    |
|---------------|--------|---------|------|------|------|
| Position      | (mm)   | (mm)    | (mm) | (mm) | (mm) |
| 1 o'clock     | 12.1   | 11.7    | 12.4 | 11.7 | 11.3 |
| 2 o'clock     | 11.8   | 12.0    | 11.4 | 11.5 | 11.3 |
| 3 o'clock     | 11.4   | 11.3    | 12.4 | 11.1 | 11.4 |
| 4 o'clock     | 10.8   | 11.0    | 11.6 | 11.2 | 11.5 |
| 5 o'clock     | 12.0   | 11.7    | 12.0 | 11.2 | 11.3 |
| 6 o'clock     | 11.8   | 11.2    | 11.8 | 11.4 | 11.4 |
| 7 o'clock     | 11.7   | 11.2    | 11.7 | 9.5  | 11.5 |
| 8 o'clock     | 11.5   | 11.0    | 10.3 | 10.8 | 11.4 |
| 9 o'clock     | 11.5   | 11.1    | 11.4 | 11.5 | 11.5 |
| 10 o'clock    | 12.0   | 11.6    | 12.0 | 12.0 | 11.4 |
| 11 o'clock    | 12.2   | 11.7    | 11.9 | 11.7 | 11.4 |
| 12 o'clock    | 12.1   | 11.8    | 12.0 | 11.5 | 11.7 |




|                             |  |                      |  |
|-----------------------------|--|----------------------|--|
| <b>Client/<br/>Facility</b> | <b>SLOFEC Vessel Inspection Report<br/>LS150</b> | <b>Page 3 of 4</b>   |  |
| <b>BT<br/>Vessel</b>        | <b>Final Inspection Report</b>                   | <b>K0xx-13/Jxx22</b> |  |

### Ultrasonic Inspection Results

#### Slofec Deadzones around Nozzle/Manway

A UT reading was scanned 180mm around all nozzles and manways as depicted below.

| Nozzle/Manway | UT Reading (mm) |
|---------------|-----------------|
| Area 1        | 8.8             |
| Area 2        | 8.3             |
| Area 3        | 8.0             |
| Area 4        | 7.7             |
| Area 5        | 8.4             |
| Area 6        | 8.2             |

|                             |  |                      |  |
|-----------------------------|--|----------------------|--|
| <b>Client/<br/>Facility</b> | <b>SLOFEC Vessel Inspection Report<br/>LS150</b> | <b>Page 4 of 4</b>   |  |
| <b>BT<br/>Vessel</b>        | <b>Final Inspection Report</b>                   | <b>K0xx-13/Jxx22</b> |  |

### Ultrasonic Inspection Results

#### Slofec Deadzones around Circumferential Weld and Saddle

A UT reading was scanned 180mm around all circumferential welds and welds of the vessel saddle as depicted below. No body of welds were scanned using shear wave. Due to time constraints only from 3 o'clock to 9 o'clock were scanned (underside of vessel).

| Weld No.       | UT Reading (mm) |
|----------------|-----------------|
| 1              | 8.3             |
| 2              | 5.2             |
| 3              | 6.7             |
| 4              | 7.7             |
|                |                 |
| Eastern Saddle | 5.2             |
| Western Saddle | 5.0             |